

Federal Communications Commission

Registration Number: 184111

## Proof of Compliance under FCC Supplier's Declaration of Conformity

Page 1 of 2

Applicant:

Cermate Technologies Inc.

7F.-1, No.168, Liancheng Rd. Zhonghe Dist., New  
Taipei City 235, Taiwan

Equipment Under Test:

Human machine interface

Test Model No.:

PM204

Reference Model No.:

See page 2

Trade Name:

N.A.

Power Supply:

Input: 12V~24V, 0.8A

Battery: DC3V 240mAh

Test Standard(s):

FCC 47 CFR Part 15 Subpart B: 2022

File Number:

AT18230EC301189

Report Number:

18230EC30118901

Is here with confirmed to comply with the requirements set out in the FCC 47 CFR Part 15 Subpart B and CISPR PUB. 22 and the measurement procedures were according to ANSI C63.4-2014. This said equipment in the configuration described in this report shows the maximum emission levels emanating from equipment are within the compliance requirements. The test results of this report relate only to the tested sample identified in this report.



Certified by



Jul. 13, 2023

Date

KingKong Jin

Shenzhen Anbotek Compliance Laboratory Limited

1/F, Building D, Sogood Science and Technology Park, Sanwei community,  
Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.518128

Tel: (86)755-26066440

Fax: (86)755-26014772

Http://www.anbotek.com

Email: [service@anbotek.com](mailto:service@anbotek.com)



### Proof of Compliance under FCC Supplier's Declaration of Conformity

Page 2 of 2

#### Model List:

PM204-xxx0, FM204-xxx0, RM204-xxx0, KM204-xxx0, GM204-xxx0, KSM-204, Xpm204-xxx0, AST-204CHS-0, LCM204-xxx0, IPM204-xxx0, PMM204-xxx0, LKM204-xxx0, SM204-xxx0, HM204-xxx0, WM204-xxx0, UM204-xxx0, CM204-xxx0, VM204-xxx0, MHM204-xxx0, GPM204-xxx0, SPM204-xxx0  
(The first x represents the number 0 or 1, "0" means LCM 480\*272, "1" means LCM 800\*480; The second x represents the letters A,B,C or D, "A" represents the work gauge screen LCM (-30~70°C), "B" represents the work gauge screen LCM (-10~60°C), "C" represents the business gauge LCM (0-50°C), "D" represents the custom specification LCM; The third x represents the number 22 or 33, "22" for serial port 2, "33" for serial port 3)



Certified by

Jul. 13, 2023  
Date



*KingKongJin*

KingKong Jin

**Shenzhen Anbotek Compliance Laboratory Limited**

1/F, Building D, Sogood Science and Technology Park, Sanwei community,  
Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.518128  
Tel: (86)755-26066440 Fax: (86)755-26014772  
Http://[www.anbotek.com](http://www.anbotek.com) Email: [service@anbotek.com](mailto:service@anbotek.com)